



CERTIFICATE REGARDING SAFE DRINKING WATER

No : 888

Date : 16/06/2022

Certified that **NATIONAL PUBLIC SEN. SEC. SCHOOL, Village Chhajli (Sangrur)** was inspected by S.D.E W/S & Sanitation Department Sub Division Sunam on 30-05-2022 and found that the **NATIONAL PUBLIC SEN. SEC. SCHOOL, Village Chhajli (Sangrur)** has safe drinking water facilities as per report issued from Regional Water Testing lab, sangrur dated 09-06-2022 for the students and members of the institution.


Headmaster
National Public School
Chhajli (Sangrur)


Sub Divisional Engineer
W/S and Sanitation Sub Div
Sunam.

REGIONAL WATER TESTING LAB, SANGRUR
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

To,

National Public School Chhajli
Village Chhajli Main Road


No.: RWTL/SNG/2122/2223/00058 Dated : 09/06/2022

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 792 Dated: 30/05/2022

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 01/06/2022. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab, Sangrur



Headmaster
National Public School
Chhajli (Sangrur)



TEST REPORT

Name & Address of Customer : National Public School Chhajli Village Chhajli Main Road	Customer Reference No.	No : 792 Dated : 30/05/2022
	Sample Submitted by	Manjuar Mohd
	Date of Sample Receipt	01/06/2022
	Analysis Starting Date	03/06/2022
	Analysis completion Date	04/06/2022

Discipline : Chemical Testing		Group: Water	
Test Report No.:	RWTL/SNG/2122/2223/00058	Date of Issue :	09/06/2022
Registration no.:	RWTL/SNG/2122/REG2223/00324	Condition of Sample :	Unsealed
Source :	NA	Quantity/Type of Bottle:	500 ml / PTFE Bottle
Scheme :	NA	Location/Depth :	Tubewell 400 ft. National Public School Chhajli / 400 ft
Village :	NA	Habitation :	NA
Block:	Sunam	District :	Sangrur
Latitude :	NA	Longitude:	NA

Sample Type: Water

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.14	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	TDS	407	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.18	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	60	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	116	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	12	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	70	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.

[Signature]
Headmaster
National Public School
Chhajli (Sangrur)

[Signature]
Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab,
Sangrur

----- End of the Test Report -----