

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 863

Dated: 28/04/2025

It is certified that an inspection team headed by GURIOBAL SINGH (SPE) & YOGESH GARG (JE)

(Name of Officers with designation) from W/S & SANITATION SUB DIVISION, SUNAM PHED

inspected the NATIONAL PUBLIC SCHOOL, CHHAJLI TEH. SUNAM DISTT. SANGRUR

(Name & Address of the school) on 02/04/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RNTL/SNG/2526/00018 dated 25/04/2025

of REGIONAL WATER TESTING LAB, SANGRUR (PHED Lab) certified that the

NATIONAL PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31/03/2026

Signature with Seal:

Name

Designation:

Name & Address of the Office/ Department :

To

NATIONAL PUBLIC SCHOOL
VPO. CHHAJLI TEH. SUNAM DISTT. SANGRUR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Parveen Akhter

Secretary

Baba Farid Educational &
Social Welfare Society

BS

Principal

National Public School
Chhajli (Sangrur)

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtsangrur@gmail.com

To,

Sub Division Engineer
Sub Division Engineer Water Supply and Sanitation Sub Division, Sunam

No.: RWTL/SNG/2526/00018 Dated : 25/04/2025

Subject : Testing Reports of Water Samples.

Reference: Yqr Letter/SRF No. 684 Dated: 02/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 03/04/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report

Parveen Akhtar

Secretary
Baba Farid Educational &
Social Welfare Society

Sangrur

Authorized Signatory
For, Regional Water Testing Lab
Sangrur

BS
Principal
National Public School
Chhajji (Sangrur)





TC-12990

TEST REPORT

Name & Address of Customer : Sub Division Engineer Sub Division Engineer Water Supply and Sanitation Sub Division, Sunam		Customer Reference No.	No : 684 Dated : 02/04/2025
		Sample Submitted by	
		Date of Sample Receipt	03/04/2025
		Analysis Starting Date	03/04/2025
		Analysis completion Date	08/04/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC12990250000206F	Sample Type :	Water
Test Report No.:	RWTL/SNG/2526/00018	Date of Issue :	25/04/2025
Registration no.:	RWTL/SNG/REG2526/00008	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	National Public Sen. Sec. School, Chhajli / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.92	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	349	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.72	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity(CaCO ₃)	256	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness(CaCO ₃)	136	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	30	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	15	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	38	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ramesh Jhorar
Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

Baba Farid
Secretary
Baba Farid Educational &
Social Welfare Society

End of the Test Report

BS
Principal
National Public School
Chhajli / Sangrur